

PART A: Models PVI-6000-OUTD-US, PVI-6000-OUTD-US-A, and PVI-6000-OUTD-US-W

	Model PVI-6000-OUTD-US & PVI-6000-OUTD-US-A	Model PVI-6000-OUTD-US-W	
Maximum Input Voltage (DC)	600 V dc	600 V dc	
Range of Input Operating Voltage (DC)	90-580 V dc, 360 V dc nominal	50-580 V dc, 360 V dc nominal	
Maximum Input Current (DC)	18 A (Each Input - 2 provided)	36 A	
Maximum Input Short Circuit Current (DC)	22 A (Each Input - 2 provided)	44 A	
Maximum Utility Backfeed Current (AC)	0 A	0 A	
Output Power Factor Rating	1	1	
Operating Voltage Range (AC) (See Note 2)	244-304 V ac for 277 V ac configuration 211-264 V ac for 240 V ac configuration 183-228 V ac for 208 V ac configuration	244-304 V ac for 277 V ac configuration 211-264 V ac for 240 V ac configuration 183-228 V ac for 208 V ac configuration	
Operating Frequency Range (HZ)	59.3-60.5 Hz (Default)	59.3-60.5 Hz (Default)	
Field Adjustable Operating Frequency Range (HZ)	57.0-59.8 Hz, 60.2-63.0 Hz	57.0-59.8 Hz, 60.2-63.0 Hz	
Nominal Output Voltage (AC) (See Note 2)	277 V ac / 240 V ac / 208 V ac	277 V ac / 240 V ac / 208 V ac	
Normal Output Frequency	60 Hz	60 Hz	
Continuous Output Current (AC)	24 A / 28 A / 30 A	24 A / 28 A / 30 A	
Maximum Continuous Output Power (AC) (See Note 4)	@ 50°C ambient: 6000 W	@ 50°C ambient: 6000 W	
Maximum Output Fault Current and Duration	32 A (See Note 8)	32 A (See Note 8)	
Maximum Output Overcurrent Protection	30 A / 35 A/ 40 A	30 A / 35 A/ 40 A	
Utility Interconnection and Voltage and Frequency Trip Limits and Trip Times	See Note 9	See Note 9	
Trip Limit and Trip Time Accuracy	Voltage: +/- 2% Frequency: +/- 0.10 Hz Time: 2 grid cycles (33 ms @ 60 Hz)	Voltage: +/- 2% Frequency: +/- 0.10 Hz Time: 2 grid cycles (33 ms @ 60 Hz)	
Normal Operation Temperature Range	-25°C to 60°C (See Note 4)	-25°C to 60°C (See Note 4)	
Output Power Temperature Derating and Maximum Full Power Operating Ambient	-25°C to 60°C (See Note 4)	-25°C to 60°C (See Note 4)	
Enclosure Rating Type	4X	4X	



Page 2 of 8

Device	Device Version	Device Checksum
Rev. Number Microprocessor	C.0.1.6	97CA
Rev. Number DC-DC Converter	A.1.0.8	853E
Rev. Number Inverter	B.1.0.B	A421

Alternate Device Version (Referred to Alternate Microcontroller, Atmel, Type ATMEGA 256-16-AU):

		Jr
Device	Device Version	Device Checksum
Rev Number DC-DC Converter	A.1.0.8	853E
Rev. Number Inverter	B.1.0.B	A421
Rev. Number Microprocessor	C.1.4.0	3382

Alternate Device Version (Referred to very high voltage field adjustable time setting):

Device	Device Version	Device Checksum
Rev Number DC-DC Converter	A.1.0.8	853E
Rev. Number Inverter	B.1.1.5	1398
Rev. Number Microprocessor	C.1.4.1	F68D

For Model PVI-6000-OUTD-US-A

Device	Device Version	Device Checksum
Rev Number DC-DC Converter	A.1.0.8	853E
Rev. Number Inverter	B.1.0.B	A421
Rev. Number Microprocessor	C.0.4.0	8914

Alternate Device Version for Model PVI-6000-OUTD-US-A


Device	Device Version	Device Checksum
Rev Number DC-DC Converter	A.1.0.8	853E
Rev. Number Inverter	B.1.1.5	1398
Rev. Number Microprocessor	C.0.4.1	3292


Notes:

- 1. Inverter, Models PVI-6000-OUTD-US, PVI-6000-OUTD-US-A, and PVI-6000-OUTD-US-W have been evaluated for use in utility-interactive applications.
- 2. The output of Inverter, Models PVI-6000-OUTD-US, PVI-6000-OUTD-US-A, and PVI-6000-OUTD-US-W may be 277 V ac, 240 V ac or 208 V ac which is user settable based on the utility system.
- 3. Inverter Models PVI-6000-OUTD-US, PVI-6000-OUTD-US-A, and PVI-6000-OUTD-US-W have been evaluated for outdoor use.

Page 3 of 8

 Maximum output power can be delivered only with an input voltage range of: 200-530 V dc for 208 V ac configuration 200-530 V dc for 240 V ac configuration 200-530 V dc for 277 V ac configuration






- 5. Inverter, Models PVI-6000-OUTD-US, PVI-6000-OUTD-US-A and PVI-6000-OUTD-US-W are intended to be used in an ungrounded power system in conjunction with the requirements specified in the National Electrical Code, ANSI/NFPA 70, 2005 Ed, section 690.35.
- 6. Inverter Model PVI-6000-OUTD-US-W is intended for operation with an AC Generated supply (i.e. wind or hydro); this inverter is intended to receive an input supply from a certified interface module (rectifier-controller which converts AC voltage from an AC generator into a regulated DC voltage).
- 7. All models meet the surge requirements of IEEE C62.41.2-2002, Location Category B (6kV). Tests were performed using ring wave and combination waveforms, both polarities, for common mode and differential model coupling, 20 pulses each test. After surge testing the units were optional with control functionally verified by frequency and voltage disconnect tests.



8. Maximum Output Fault Current and Duration:

Short Circuit Test Results			
Output Voltage (Vac) Peak Current value (A) RMS Current Value (Aac) Durat		Duration (ms)	
208	36.25	25.63	82
240	36.50	25.81	107
277	31.75	22.45	80



9. Utility Interconnection and Voltage and Frequency Trip Limits and Trip Times:

Condition	Simulated utility source		Maximum time (sec) at 60
	Voltage (V)	Frequency (Hz)	Hz ^a before cessation of
			current to the simulated
			utility
A	$< 0.50 \mathrm{V_{nor}}^{\mathrm{b} (**)}$	Rated (60 Hz)	0.16 (Fixed)
В	$0.50 \text{ V}_{\text{nor}}^{\text{b}} \le \text{V} < 0.88 \text{ V}_{\text{nor}}$	Rated (60 Hz)	2 (Fixed)
	(Adj. See Notes Below)		
С	$1.10 \text{ V}_{\text{nor}}^{\text{b}} < \text{V} < 1.20 \text{V}_{\text{nor}}(*)$	Rated (60 Hz)	1 (Fixed)
	(Adj. See Notes Below)		
D	$1.20V_{nor} \le V(*)$	Rated (60 Hz)	0.16 (Fixed)
			(Adj. 0.001 to 0.16 sec)
Е	Rated	f > 60.5 Hz (Default)	0.16 (Default)
		(Adj. 60.2 to 63.0 Hz)	(Adj. 0.16 to 300 sec)
F	Rated	f < 59.3 Hz (Default)	0.16 (Default)
		(Adj. 59.8 to 57.0 Hz)	(Adj. 0.16 to 300 sec)
G	Rated	f < 57.0 Hz	0.16
Н	Rated	f > 63.0 Hz	0.16

When a utility frequency other than 60 Hz is used for the test, the maximum number of cycles it takes to cease to export power to the simulated utility shall not exceed the number of cycles a utility frequency of 60 Hz takes regardless of the time the inverter takes to cease to export power to the simulated utility.

- b V is the nominal output voltage rating.
- (*) Note: For model at 277V High Voltage is fixed at 110% V_{nor} and Very High Voltage is fixed at 111% V_{nor}
- (**) Note: For model at 208V Very Low Voltage is fixed at 55% V_{nor} and Minimum Adjustable Low Voltage is 55% V_{nor}
- 10. All above models in this series may include expansion board with wireless antennae option and will be identified with model designation including "–Z" suffix.