



Texas Commission on Environmental Quality

Protecting Texas by Reducing and Preventing Pollution

April 30, 2025

Delivered Via Certified Mail DWQ/NOV/02/2950

CITY OF TIMPSON
DEBRA PATE SMITH, MAYOR
PO BOX 369
TIMPSON, TX 75975-0369

SUBJECT: Notice of Violation: TOTAL TRIHALOMETHANE (TTHM) MCL, LRAA
30 TAC §290.115(f) - MCL Based on Locational Running Annual Average (LRAA)
CITY OF TIMPSON - PWS ID NO. TX2100003
SHELBY County, TX

This letter contains important information about compliance requirements for your public water system.

Attention: Public Water System Owner / Manager / Operator

The Texas Commission on Environmental Quality (TCEQ) has determined that **CITY OF TIMPSON** has violated the maximum contaminant level (MCL) for total trihalomethanes in the water supplied to its customers. These violations occurred during quarter two 2025. Title 30 Texas Administrative Code (30 TAC) §290.115 describes how we determined that these violations occurred.

The MCL for total trihalomethanes is 0.080 milligrams per liter (mg/L) based on a locational running annual average (LRAA). From the data contained in the attached report, we determined a compliance value for total trihalomethanes in quarter two 2025 of 0.107 mg/L for DBP2-02 and 0.111 mg/L for DBP2-01.

Your public water system is required to issue public notification to your customers about the MCL violation as soon as possible, but no later than 90 days after the date the violation was identified in accordance with 30 TAC §290.122. You are required to repeat the notice every three months for as long as the violation persists. You should use the same method that you used for the initial notice.

The TCEQ recommends that the public water system provide a copy of the Public Notice(s) to local and state officials, such as Mayors, City Council Members, County Commissioners, Judges, and/or State Representatives, that are located in or that represent the affected area(s) served by the system.

The public notice must use the enclosed mandatory language for every notice, and include a brief statement about how you plan to address the problem as described in 30 TAC §290.122(d). This statement must describe what actions the water system is taking to correct the violation and when the water system expects to return to compliance. Please send a copy of the public notification and a signed Certificate of Delivery for Public Notice to this office within 10 days after it has been delivered. Mail to:

Drinking Water Inventory and Protection Team
TCEQ Public Drinking Water (MC-155)
P.O. Box 13087
Austin TX 78711-3087

Please note that enforcement actions resulting from noncompliance may result in fines for each violation.

Violation Sample Results Report:
CITY OF TIMPSON PWS ID: TX2100003

DBP2-01

Violation ID Number	Monitoring Period	Violation Description	Analyte Description	Calculated Compliance Value
90041448	2Q2025	MCL, LRAA	TTHM	0.111 mg/L

Results for Quarter 2 of 2025: TTHM

Sample ID:Q2513263001 04/03/2025 DBP2-01 161 GARRISON, TIMPSON 102.0 µg/L

Results for Quarter 1 of 2025: TTHM

Sample ID:Q2500211002 01/06/2025 DBP2-01 161 GARRISON, TIMPSON 110.0 µg/L

Results for Quarter 4 of 2024: TTHM

Sample ID:Q2444833003 10/22/2024 DBP2-01 161 GARRISON, TIMPSON 112.0 µg/L

Results for Quarter 3 of 2024: TTHM

Sample ID:Q2432888001 07/31/2024 DBP2-01 161 GARRISON, TIMPSON 118.0 µg/L

DBP2-02

Violation ID Number	Monitoring Period	Violation Description	Analyte Description	Calculated Compliance Value
90041447	2Q2025	MCL, LRAA	TTHM	0.107 mg/L

Results for Quarter 2 of 2025: TTHM

Sample ID:Q2513263002 04/03/2025 DBP2-02 250 ROSS GROVES DRIVE, TIMPS 113.0 µg/L

Results for Quarter 1 of 2025: TTHM

Sample ID:Q2500211003 01/06/2025 DBP2-02 250 ROSS GROVES DRIVE, TIMPS 114.0 µg/L

Results for Quarter 4 of 2024: TTHM

Sample ID:Q2444833010 10/22/2024 DBP2-02 250 ROSS GROVES DRIVE, TIMPS 95.3 µg/L

Results for Quarter 3 of 2024: TTHM

Sample ID:Q2432888002 07/31/2024 DBP2-02 250 ROSS GROVES DRIVE, TIMPS 105.0 µg/L